

RESIDENTIAL SMOKE ALARMS

(Single Family Homes)

WHEN REQUIRED:

- In all new construction or additions, alterations, or repairs over \$1,000.00.
- When additional sleeping rooms are added.

POWER SOURCE:

- In new construction or extensive remodeling regular, hard wired alarms with battery backup.
- In existing buildings or buildings without commercial power may be solely battery powered.

LOCATION WITHIN DWELLING UNITS:

- In each sleeping room.
- In all corridors to sleeping rooms centrally located in the corridor.
- On every floor and in the basement. Where a story is split into two or more levels, the detector shall be in the upper level except when the tower level has a bedroom. Levels are separated by doors or walls that restrict the flow of smoke from the lower level to the upper level will be considered separate floors.
- In dwelling units where the ceiling of the room open to the hall serving bedrooms exceeds the hall by twenty-four (24) inches.

AUDIBILITY:

- Detectors shall sound an alarm audible in all sleeping areas of the dwelling unit in which they are located.

Municipal Inspections Inc.
601 Main Street Box 99
Elko New Market, MN. 55054
Email: Inspectenm@outlook.com
Phone: 952-461-4777, Fax: 952-461-2782