

Municipal Inspections, Inc.
25275 Vergus Ave.
New Prague, Minnesota 56071
(952) 461-4777 - FAX: (952) 461-2782

WATER HEATER HANDOUT

- ☞ **Inspection Record card or summary** permit sheet shall be available and shall remain on the job site until the final inspection has been made.
- ☞ Call (952) 461-4777 to schedule a final inspection. For same day inspection, please call between 8:00 a.m. and 9:00 p.m.
- ☞ **Water heater vent** must comply with the listing. Read the installation instructions.
- ☞ **Combustion air** required same size as flue or can be installed into return air duct with an opening in the supply air into the utility room.
- ☞ **Temperature & Pressure valve** required to be discharged to within 18" of floor, not closer than 1-1/2" of floor.
- ☞ **Maxitrol regulator** must be installed horizontal with a drip tee on the high pressure side before Maxitrol.
- ☞ **Gas valve** required with union on water heater and installed in the same room as the water heater.
- ☞ **Drip tee** installed on water heater gas line.
- ☞ **Vent connector** must have minimum 1/4" pitch up to flue.
- ☞ **Single wall vent connector** must have 6" clearance to combustibles.
- ☞ **Class B Vent** connector must have minimum 1" clearance to combustibles.
- ☞ **Water shut off valve** must be installed on the cold water side.
- ☞ **Clearances** in front of water heater to be 24" and 1" minimum on sides and backs.
- ☞ **Access** to water heater cannot be through a bedroom, bathroom or closet.